

PRODUCT CONFORMITY CERTIFICATE

This is to certify that the

MSFM S2U Multi Sensor Flow Monitor

Manufactured by:

Detectronic Ltd

Regent Street,
Whitewalls Industrial Estate,
Colne, Lancashire
BB8 8LJ

has been assessed by Sira Certification Service
and for the conditions stated on this certificate complies with:

**MCERTS Performance Standards for Continuous Water Monitoring Equipment,
Version 2.4 dated February 2013**

Certification Ranges :

0 to 30l/s for 197mm channel
0 to 20l/s for 152mm pipe
0 to 25l/s for 188mm pipe
0 to 30l/s for 244mm pipe

Project No.: 70111535
Certificate No: Sira MC180336/01
Initial Certification: 15 August 2018
This Certificate issued: 16 August 2018
Renewal Date: 14 August 2023

Emily Alexander
Deputy Certification Manager

MCERTS is operated on behalf of the Environment Agency by

Sira Certification Service

Unit 6, Hawarden Industrial Park
Hawarden, Deeside, CH5 3US
Tel: +44 (0)1244 670 900



*The MCERTS certificate consists of this document in its entirety.
For conditions of use, please consider all the information within.
This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Certificate Contents

Approved Site Application	2
Basis of Certification	2
Product Certified.....	2
Certified Performance	3
Description.....	5
General Notes	5

Approved Site Application

Any potential user should ensure, in consultation with the manufacturer, that the monitoring system is suitable for the intended application. For general guidance on monitoring techniques refer to the Environment Agency Monitoring Technical Guidance Notes available at www.mcerts.net

The product is suitable for use, where it is appropriate, for regulated applications such as abstraction, effluent discharge, ultraviolet disinfection and industrial processing.

Basis of Certification

This certification is based on the following Test Report(s) and on Sira's assessment and ongoing surveillance of the product and the manufacturing process:

- Detectronic MCERTS MSFM Open Channel Flow Meter. Issue 2, dated 28/03/2018
- WRc Witness testing, Report ref: UC12499/14677-6 dated May 2017

Product Certified

The MSFM S2U Multi Sensor Flow Monitor measuring system consists of the following parts:

- Multi sensor flow meter control unit
- PDCR1830 hydrostatic pressure transducer
- ESPF2 ultrasonic Doppler velocity sensor

This certificate applies to all instruments fitted with Firmware version 4.04 (serial number 20132771955) onwards.

Certificate No : Sira MC180336/01
This Certificate issued : 16 August 2018

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Certified Performance

The instrument was evaluated for use under the following conditions:

Ambient Temperature Range: -25°C to +60°C

The instrument meets MCERTS Class 3 requirements for the combined performance characteristic as specified in Table 7 of the MCERTS performance standard. Details of individual performance characteristics are summarised below:

Results are expressed as error % of certification range, unless otherwise stated.

Test	Results expressed as % of the certification range				Other results	MCERTS specification
	<0.5	<1	<2	<5		
Protection against unauthorised access	The unit is password protected					Clause 3.1.2
Units of measurement	The indicating device and output are scaled in metric units					Clause 3.1.3
Indicating device	Indicating device displays logged readings as volumetric flow-rate					Clause 3.1.4
Flow computation	Flow is calculated from level and velocity					Clause 3.1.11
Combined performance characteristic						8% (Class 3) Table 7
197mm				2.63	6.65	
152mm				2.71		
188mm						
244mm				4.33		
Mean Error						5.17
Repeatability				2.23		4% (Class 3)
Supply voltage				2.06		2.5% (Class 4)
0 to 13 V DC						
Fluid Temperature						2% (Class 3)
(+5.6°C to +29.7°C)				-1.05		
Ambient air temperature						1% (Class 2)
(-25°C to +60°C)				-0.66		
Relative Humidity						0.5% (Class 1)
(95%RH)				-0.15		
Effect of conduit size						Clause 6.3.17 To be reported
152mm				1.98		
188m					2.23	
244m					3.51	

Certificate No : Sira MC180336/01
 This Certificate issued : 16 August 2018

*This certificate may only be reproduced in its entirety and without change
 To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Test	Results expressed as % of the certification range				Other results	MCERTS specification
	<0.5	<1	<2	<5		
Fill level						Clause 6.3.18 To be reported
197mm				-4.7		
152mm				-3.34		
188mm			-1.65			
244mm			1.99			
Response time					15 seconds	<30 seconds
Warm up time					5 minutes	Clause 6.1.2 To be reported
Error under field test conditions	Max error 7.9% Min error -7.9% Mean error -0.64% Proportion of errors $\leq 5\%$ = 82% Proportion of errors $\leq 8\%$ = 100%					Clause 7.3.1 8% (Class 3)
Up time					100%	Clause 7.4.1 >95%
Maintenance					3 months	To be reported

Note 1: The following tests are not applicable to the flowmeter:

- | | |
|----------------------------------|-----------------------------------|
| 6.3.4 Output impedance | 6.3.15 Ancillary devices |
| 6.3.7 Incident light | 6.3.16 Effect of conduit material |
| 6.3.8 Sensor location | 6.3.20 Vibration |
| 6.3.9 Presence of stray currents | |
| 6.3.10 Direct solar radiation | |
| 6.3.13 Bi-directional flow | |
| 6.3.14 Flow reversal | |

Certificate No : Sira MC180336/01
 This Certificate issued : 16 August 2018

*This certificate may only be reproduced in its entirety and without change
 To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*

Description

The Detectronic MSFM S2U ultrasonic flowmeter is a self-contained battery powered GSM Data-logger intended to be used for open channel flow measurement.

The flowmeter uses a submerged sensor which is profiled to resist fouling. An integrated temperature sensor records the water temperature, a pressure transducer is used to calculate depth, and a velocity sensor which employs the Doppler principle is used to measure flow velocity.

Measurements are recorded at intervals selected by the user and flow rates are calculated using a temperature compensated cross sectional area and velocity method. Recorded information can be downloaded on site or is transmitted via GPRS to a secure website.

General Notes

1. This certificate is based upon the equipment tested. The Manufacturer is responsible for ensuring that on-going production complies with the standard(s) and performance criteria defined in this Certificate. The Manufacturer is required to maintain an approved quality management system controlling the manufacture of the certified product. Both the product and the quality management system shall be subject to regular surveillance according to 'Regulations Applicable to the Holders of Sira Certificates'. The design of the product certified is defined in the Sira Design Schedule V01 for certificate No. Sira MC180336/00
2. If certified product is found not to comply, Sira Certification Service should be notified immediately at the address shown on this certificate.
3. The Certification Marks that can be applied to the product or used in publicity material are defined in 'Regulations Applicable to the Holders of Sira Certificates'.
4. This document remains the property of Sira and shall be returned when requested by the company.

Certificate No : Sira MC180336/01
This Certificate issued : 16 August 2018

*This certificate may only be reproduced in its entirety and without change
To authenticate the validity of this certificate please visit www.csagroupuk.org/mcerts*